

## TABLE 1

SPACER THICKNESS & LENGTH TABLE			
	PIPE DIAMETER (NOMINAL)	MINIMUM THICKNESS	SPACER LENGTH
	25 - 38mm	2mm	150mm
	50mm	2mm	300mm
	75 - 100mm	2.3mm	300mm
	150mm	3mm	300mm
	200mm	3.8mm	300mm
	250mm	4.3mm	300mm
	300mm	4.8mm	400mm
	350mm	5.8mm	400mm
	400mm	6.4mm	400mm
	500mm +	8mm	400mm

## **NOTE**

- 1. APPLICATIONAL SPACER ON METALLIC PIPE REQUIRED WHEN DIM 'A' AND/OR DIM 'B' IS LESS THAN 300mm OR AS SPECIFIED BY DESIGNER.
- 2. REFER TO TABLE 1 FOR RECOMENDED SPACER DIMENSIONS.
- 3. SPACER SHALL MEET THE REQUIREMENTS OF REGION OF PEEL WATERMAIN, STORM SEWER AND SANITARY SEWER DESIGN CRITERIA ADDENDUM, SECTION 3.6.
- 4. FOR BONDED FOREIGN PIPE ARRANGEMENTS, SEE DRAWING NUMBER 3-2-3 FOR TEST STATION AND CROSS BONDING DETAIL.

<b>F</b> Region	n of Peel
	orking for you

PUBLIC WORKS STANDARD DRAWING

## REV. DATE: FEBRUARY 2015

APPROVED BY	DRAWN BY	
WT	AECOM	
STD. DWG. NUMBER	SCALE	
3-2-4	N.T.S.	

## PIPE INSULATION SPACER