

NOTE

- 1. REFER TO TYPICAL LINE VALVE CHAMBER DETAIL 1 OF 2 (STD. DWG. 1-3-30) FOR PLAN VIEWS.
- 2. ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.

Region of Peel working with you

PUBLIC WORKS STANDARD DRAWING

TYPICAL LINE VALVE CHAMBER FOR 750 DIAMETER CONCRETE PRESSURE PIPE DETAIL 2 OF 2

RF\/	DATE:	APRII	2014

APPROVED BY

A.P.

AINLEY GROUP

STD. DWG. NUMBER

SCALE

1-3-31

N.T.S.