

- 1. BY-PASS MAY BE ONE PIPE SIZE SMALLER THAN METER SIZE.
- 2. 50mm GALVANIZED CONDUIT SHALL BE INSTALLED FROM INSIDE CHAMBER WALL TO SUITABLE LOCATION 2000mm MIN. OUTSIDE TRAFFIC AREA, AS PER REGION STD.DWG. 1-2-3.
- 3. IF METER CHAMBER IS LOCATED NEAR STREET LINE, VALVE TO BE AT STREET LINE.
- 4. PROTECTUS METER SHALL BE USED FOR PRIVATE HYDRANTS ON A BULK METER SYSTEM.
- 5. ALL INTERNAL AND EXTERNAL VALVES, FITTINGS, THROUGH WALL METAL PIPING AND MECHANICAL RESTRAINTS TO BE C/W DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.

