

NOTE

- 1. IF METER CHAMBER IS LOCATED NEAR THE STREET LINE, VALVE SHALL BE AT STREET LINE.
- 2. 50mm GALVANIZED CONDUIT SHALL BE INSTALLED FROM INSIDE CHAMBER WALL TO A SUITABLE LOCATION 2000mm MIN. OUTSIDE VEHICLE TRAFFIC AREA, AS PER STD. DWG. 1-2-3.
- 3. BY-PASS MAY BE ONE SIZE SMALLER THAN METER SIZE.
- 4. ALL INTERNAL AND EXTERNAL VALVES, FITTINGS, THROUGH WALL METAL PIPING AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.

