

NOTE

- 1. IF THE WATERMAIN IS NOT AT THE STANDARD OFFSET, THE LOCATION OF THE HYDRANT TO BE AS PER CONSTRUCTION DRAWINGS.
- 2. BACKFILL TRENCH WITH GRANULAR 'B' COMPACTED TO 100% STD. PROCTOR DENSITY.
- 3. MECHANICAL RESTRAINTS REQUIRED ON ALL PVC HYDRANT LATERALS INCLUDING VALVES AND FITTINGS AS PER REGION STANDARD DRAWING 1-5-9.
- 4. ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE PROTECTED WITH 3 PART CORROSION PREVENTION SYSTEM, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.
- 5. TRACER WIRE AS PER REGION STANDARD DRAWING 1-7-10.



PUBLIC WORKS STANDARD DRAWING

HYDRANT SETTING FOR CONCRETE PIPE REV. DATE: MARCH 2018

APPROVED BY	DRAWN BY
E.O.	AINLEY GROUP
STD. DWG. NUMBER	SCALE
1-6-2	N.T.S.