



TYPE OF CONNECTION	REQUIRED SERVICE SIZE (mm)
SAMPLING	19 Ø
FLUSHING	38 Ø
PRESSURE TRANSMITTER	19 Ø

DEPTH OF COVER (mm)	'A'	'B'
ON UNIMPROVED ROADS	1950	2100
ON CURB AND GUTTER ROADS	1500	1700

NOTE

1. SAMPLING STATIONS SHALL HAVE 12.5mm 316 STAINLESS STEEL WATERWAY.
2. SAMPLING STATIONS SHALL BE EQUIPPED WITH A 9.5mm 316 STAINLESS STEEL VENT TUBE TO ENABLE EACH STATION TO BE PUMPED FREE OF STANDING WATER TO PREVENT FREEZING AND TO MINIMIZE BACTERIA GROWTH.
3. ALL WORKING PARTS SHALL BE REMOVABLE FROM ABOVE GROUND WITH NO DIGGING.