

## NOTICE OF COMPLETION

### Zone 6 Reservoir And Feeder mains Class Environmental Assessment Study

#### The Study


The Region of Peel has completed a Class Environmental Assessment (EA) for the construction of a water reservoir and feeder main to service areas of north Brampton and Caledon (known as the Zone 6 water distribution area). A requirement for additional fire and emergency storage was identified for these areas using facilities that are not dependent on pumped water supply.

The Region's Water and Wastewater Masterplan 2007 update recommended the additional storage come from an in-ground reservoir and new feeder mains, and the proposed Zone 6 water reservoir and feeder mains provides a viable solution that meets this objective.

#### The Process

The study follows a planning process that includes:

- \* Public and review agency consultation
- \* Evaluation of solutions
- \* Review of possible locations for the storage facility and underground pipes
- \* Assessment of potential environmental impacts
- \* Identification of reasonable measures to mitigate impacts



#### Environmental Study Report

The Environmental Study Report (ESR) is being placed on public record for a 30-day calendar review period in accordance with the requirements of the Municipal Class EA. Subject to comments received as a result of this notice and the necessary approvals, the Region of Peel intends to proceed with the detailed design and construction as documented in the ESR.

The ESR will be available for public review at the following locations beginning September 26, 2011.

#### Region of Peel

Regional Clerk's Department  
10 Peel Centre Dr.  
Suite A, 5th Floor  
Brampton  
Mon. to Fri. 8:30 a.m. - 4:30 p.m.

#### Town of Caledon

Town Clerk's Department  
6311 Old Church Rd.  
Caledon  
Mon-Fri: 9 a.m. - 4:30 p.m.

#### Margaret Dunn Valleywood

**Branch - Public Library**  
20 Snelcrest Dr.  
Caledon  
See Library Hours

#### Comments

Should you have concerns with this project please provide written comments to Italia Ponce at the address listed below within the review period of **September 26, 2011 to October 26, 2011**.

If concerns arise during the prescribed review period that cannot be resolved through discussion with the Region of Peel, a request that the Minister of the Environment make an order for the project to comply with Part II of the Environmental Assessment Act can be made. This would then subject the project to an individual environmental assessment. This request (commonly referred to as a Part II Order or "bump up" request) must be received within the 30-day calendar review period by the Minister at the address listed below.

#### The Honourable John Wilkinson Minister of the Environment

77 Wellesley Street West  
11th Floor, Ferguson Block  
Toronto, ON  
M7A 2T5

A copy of the request must also be sent to:

#### Ms. Italia Ponce, P.Eng.

**Project Manager - Region of Peel**  
10 Peel Centre Drive  
Brampton, ON L6T 4B9  
Tel: 905-791-7800 ext. 4583  
Fax: 905-791-0728  
E-mail: [italia.ponce@peelregion.ca](mailto:italia.ponce@peelregion.ca)

If no request is sent to the Minister of the Environment and received by October 26, 2011, the Region may proceed with the detailed design and construction of the project as outlined in the ESR.

For further information, please visit the Region's website at  
[www.peelregion.ca/pw/water/environ-assess/zone6-reservoir.htm](http://www.peelregion.ca/pw/water/environ-assess/zone6-reservoir.htm)

This notice was first issued on September 22, 2011

With the exception of personal information, all comments will become part of the public record of the study. The study is being conducted according to the requirements of the Municipal Class Environmental Assessment, which is a planning process approved under Ontario's *Environmental Assessment Act*.