



- NOTES:**
1. THIS SCHEMATIC IS INTENDED TO DEPICT THE GENERAL PROCESS FLOW AND LAYOUT OF THE FACILITY. IT IS NOT INTENDED TO DEPICT A COMPLETE DESIGN. REFER TO ADDITIONAL REQUIREMENTS WITHIN THE DESIGN STANDARDS.
 2. PROVIDE CONCRETE EMBEDDED CHANNELS FOR TEMPORARY SLIDE PLATE FOR ISOLATION OF SLUICE GATES FOR REPAIR.
 3. PROVIDE A PROCESS PIPE CLEAN-OUT CONNECTION ON THE SUCTION LINE OF EACH PUMP.
 4. REFER TO ELECTRICAL AND INSTRUMENTATION DRAWINGS FOR ADDITIONAL REQUIREMENTS.

	PUBLIC WORKS STANDARD DRAWING		REV. DATE: APRIL 2021	
	SEWAGE PUMPING STATION TYPE IV RATED CAPACITY > 500 L/s		APPROVED BY MNB	DRAWN BY GM BluePlan
			STD. DWG. NUMBER SPS-105	SCALE Not to Scale