

## **NOTE**

- 1. STANDARD FOR SERVICE MORE THAN 5000mm IN LENGTH.
- 2. SERVICES LESS THAN 12000mm IN LENGTH MAIN VALVE (3) TO BE TIES TO THE TEE USING S.S. TIE RODS.
- 3. WHERE NO METALLIC PIPE IS USED, A 12 GAUGE TRACER WIRE TO BE INSTALLED WITH THE PIPE AND BE BROUGHT TO THE SURFACE AT ALL VALVE BOX BOXES.
- 4. BACKFILL TRENCH WITH GRANULAR 'B' COMPACTED TO 100% STD. PROCTOR DENSITY.
- 5. REFER TO O. REG. 350/06 PART PLUMBING SECTION 7.6.2.4 FOR TYPE OF BLACKFLOW PREVENTER REQUIRED.
- 6. ALL PIPING, FITTINGS, VALVES, APPURTENANCES AND MECHANICAL RESTRAINTS TO BE c/w DENSO PASTE, DENSO MASTIC AND DENSO TAPE OR APPROVED EQUAL, APPLIED TO MANUFACTURER'S RECOMMENDATIONS.

FRegion of Pec	
Working for yo	

PUBLIC WORKS STANDARD DRAWING

APPROVED BY	DRAWN BY
D.L.	AINLEY GROUP
STD. DWG. NUMBER	SCALE
1-6-4	N.T.S.

REV. DATE: APRIL 2014

FIRE LINE AND DOMESTIC CONNECTION